



CATEGORY

WIRING
DEVICES

AMMO ITEM #

TR15-DHG-RD

Company: _____

Job: _____ #Item: _____

Notes: _____

Duplex Receptacle Hospital Grade, Back & Side Wired



APPLICATION

Hospital applications

FEATURES

Decorator Tamper Resistent Receptacles

CONFIGURATION

- Wire Type: _____ Copper only
- Wire Binding screws: _____ UL498: Minimum Dia#8(.164)
Max Threads/inch = 32
- Yoke: _____ Brass
- Rated Output Current: _____ 15 A (min)
- Rated Voltage: _____ 125 V
- Nema: _____ 5-15R

SCREW TERMINALS

- (x4) #14-#12 AWG Solid, on hot, neutral terminals
- (x1) #14-#12 AWG Solid, on Ground terminals
- Hot terminal - Yellow, Neutral - White, Ground - Green
- Screw Torque: _____ minimum 20lbf-in without stripping of threads

CERTIFICATION

- UL498
- CSA Standards

MATERIAL

- Upper cover: _____ PC
- Base: _____ PC
- Protection cover: _____ PA
- Connection screw: _____ Steel (plating)
- Clamps parts: _____ Copper o plated aluminum

COLOR

Red

PACKAGING

- Inner: _____ 10
- Master: _____ 100
- UPC number: _____ 837654110874



WIRING & DEVICES



1000 COMMERCE CENTER DR ELKTON MD 21921
PHONE : (718).338.1851 FAX : (718).228.1851
orders@ammoelectric.com

www.ammoelectric.com